

The results (column H) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

CITYTOWN	ORG CODE	SCHOOL NAME	LOCATION ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ISCOM MENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
Lawrence	01490537	Lawrence: School for Exceptional Studies	001F	Kitchen Dish Sink-F	KC	LEAD	0.003	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 2		AD	9/22/2016	06:15:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	001F	Kitchen Dish Sink-F	KC	COPPER	0.01	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 2		AD	9/22/2016	06:15:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	001P	Kitchen Dish Sink-P	KC	LEAD	0.168	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 1		AD	9/22/2016	06:14:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	001P	Kitchen Dish Sink-P	KC	COPPER	0.025	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 1		AD	9/22/2016	06:14:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	002F	Water Cooler at Front Entrance/Near-F	WC	LEAD	0.03	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 4		RJ	9/22/2016	06:17:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	002F	Water Cooler at Front Entrance/Near-F	WC	COPPER	0.062	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 4		RJ	9/22/2016	06:17:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	002P	Water Cooler at Front Entrance/Near-P	WC	LEAD	0.029	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 3		AD	9/22/2016	06:16:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	002P	Water Cooler at Front Entrance/Near-P	WC	COPPER	0.086	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 3		AD	9/22/2016	06:16:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	003F	Nurse Bathroom Sink-F	NS	LEAD	ND	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 6		RJ	9/22/2016	06:18:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	003F	Nurse Bathroom Sink-F	NS	COPPER	0.005	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 6		RJ	9/22/2016	06:18:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	003P	Nurse Bathroom Sink-P	NS	LEAD	0.005	MG/L	0.001	SM 3113B	NASHOBA ANALYTICAL LLC	170908 5		RJ	9/22/2016	06:17:00	27-Sep-16
Lawrence	01490537	Lawrence: School for Exceptional Studies	003P	Nurse Bathroom Sink-P	NS	COPPER	0.056	MG/L	0.003	EPA 200.7	NASHOBA ANALYTICAL LLC	170908 5		RJ	9/22/2016	06:17:00	27-Sep-16